

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

November 12, 2014

AK INDUSTRIES, INC. KURT SNEARLY PO BOX 640 PLYMOUTH IN 46563

Re: Description: SEWAGE TANKS, POLYETHYLENE

Manufacturer: AK INDUSTRIES, INC.
Product Name: HOLDING OR PUMP TANK
Model Number(s): AKS 22200 [1000 GALLON]

(50 IN. L.L., 24 IN. MAX. DEPTH OF BURY, NOT APPROVED FOR SEPTIC; TANK DIMENSIONS = 90 IN. L X 90 IN. H X 69 IN. W; GALLON CAPACITY AT SPECIFIED LEVELS - 6 IN./59, 8 IN./92, 10 IN./127, 12 IN./160, 14 IN./200, 16 IN./239, 18 IN./282, 20 IN./325, 22 IN./371, 24 IN./418, 26 IN./463, 28 IN./513, 30 IN./558, 32 IN./619, 34 IN./669, 36 IN./714, 38 IN./763, 40 IN./809, 42 IN./849, 44 IN./892, 46 IN./932, 48 IN./968, 50

IN./1002)

Product File No: 20140285

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2019.

This approval supersedes the approval issued on 3/23/2011 under product file number 20090327.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
 department's stamp of approval. The plans and specifications must be open to inspection by an authorized
 representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product may not be installed more than 36 inches below final grade.
- A minimum 2" diameter vent must be provided on the building sewer within 12" of the connection to the tank or on the tank installed in accordance with the manufacturer instructions.
- BEDDING: Compacted aggregate confirming to tank base at depth and diameter as per manufacturer's installation instructions; dewater excavation prior to installation.

SBD-10564-E (N.10/97) File Ref: 14028501.DOC

AK INDUSTRIES, INC. Page 2 November 12, 2014

Product File No: 20140285

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S. POWTS Product Reviewer phone: (608) 267-5265 fax: (608) 267-9723 email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction